

**DISPATCH****CONFIDENTIAL**

PROCESSING ACTION

TO	Chief, [REDACTED] 25X1A	25X1A	25X1A	MARKED FOR INDEXING
INFO.				NO INDEXING REQUIRED
FROM	Chief, Real Estate and Construction Division, OL			ONLY QUALIFIED DESK CAN JUDGE INDEXING
SUBJECT	Final Comments on Contract Documents for [REDACTED] Air Conditioning Project, RE-LO 11-69, [REDACTED]			MICROFILM
ACTION REQUIRED - REFERENCES	REFERENCE: LOGISTICS 3359			

1. Final documents received 16 December 1969 have been reviewed. The plans, specifications, and associated contract documents prepared by local A&E firm appear quite well prepared and adequate except as noted. The following comments and/or suggestions are forwarded per reference.

a. Number of days to complete the contract work was not included on the bid form. When the time allowance is determined consideration should be given to all factors involved. Good workmanship is mandatory and time allowances should permit it.

b. If unusual restrictions for operational and security reasons are to be imposed, such conditions should be included in paragraph 1D20 of the general provisions.

c. If the intent is for others to repaint exposed wall surfaces after the contractor has completed all work then paragraph 1D23 is satisfactory. If not, then minimum provisions of this paragraph should include patch painting and touch-up, if practical.

d. Drawings do not include locations or details for security grilles. This item was noted in the memorandum for the record dated 26 September 1969 following meeting with [REDACTED] and the A&E.

2. Recommend site representative for this project insist upon adequate services from the A&E under provisions stipulated within the Title II section of the A&E contract. Additional site visits by [REDACTED] are recommended at the time major equipment approval is given, when delivered, during installation and at the time of system acceptance tests.

Distribution: 16

2 - [REDACTED] 16 JAN 1970 25X1A

(Continued)

CROSS REFERENCE TO	DISPATCH SYMBOL AND NUMBER	DATE
	LOG 70-2	15 JAN 1970
	CLASSIFICATION	HQS FILE NUMBER
		25X1A 25X1A
1 - OL/Registry 1 - OC/SCD ① - OL/RECD Official 1 - OL/RECD/EB Chrono 1 - OL Reader File	<b>CONFIDENTIAL</b>	
	OFFICE	OFFICER
	OL/RECD/EB	TYPIST
	OFFICE SYMBOL	DATE
	OC/SCD/FEB	OFFICER'S NAME
OFFICE SYMBOL	DATE	OFFICER'S SIGNATURE
OL/RECD	13 JAN 1970	[REDACTED]

25X1A

25X1A

**DISPATCH**

CONTINUATION OF DISPATCH	CLASSIFICATION	DISPATCH SYMBOL AND NUMBER
<p data-bbox="423 142 948 170">CONFIDENTIAL LOG 70-2</p> <p data-bbox="151 195 1086 300">The subject of funds and authorization to expend will be the subject of separate correspondence. It is planned to transfer the \$50,000 for construction and installation through established [REDACTED] channels.</p> <p data-bbox="146 369 238 399">25X1A</p> <p data-bbox="654 331 747 361">25X1A</p> <p data-bbox="654 373 993 436">[REDACTED]</p>		
FORM 53a 8-64 (40) USE PREVIOUS EDITION.	CLASSIFICATION	<input type="checkbox"/> CONTINUED PAGE NO.

Engineering Foreign ☒

25X1A

25X1A

Headquarters Area

RE-LO

3 TITLE:

MAJOR AC MODIFICATIONS/NEW INSTALLATION

AT

PROJECT ENGINEER:

3 STATUS:

COMMENTS AND SUGGESTIONS ON THE

25X1A

A-E CONTRACT DOCUMENTS HAVE BEEN

DISPATCHED TO . THE ADDITIONAL

\$50,000 REQUIRED FOR THE CONSTRUCTION &

INSTALLATION PORTION OF PROJECT (TOTAL \$65,000)

IS AVAILABLE AND IT IS PLANNED TO MAKE

THESE FUNDS AVAILABLE TO

25X1A

THROUGH ESTABLISHED

CHANNELS.

25X1A

EVERY EFFORT WILL BE MADE TO ACCOMPLISH

ALL WORK ON THIS A/C PROJECT BY THE

BEGINNING OF THE ~~WINTER~~ COOLING SEASON.

OR NO LATER THAN 1 JUNE 1970.